

Danish Indoor Climate Labelling

Certificate no. 013



Danish Indoor Climate Labelling hereby certifies that the product group:

**Gyptone Suspended Ceilings (prepainted and untreated surfaces)
with or without Activ'Air properties**

Gyproc
Saint-Gobain Denmark A/S
Hareskovvej 12
4400 Kalundborg
Denmark

Gyproc
Saint-Gobain Byggevarer AS
Habornveien 59
1630 Gamle Frederikstad
Norway

Gyproc
Saint-Gobain Sweden AB
Kalmarleden 50
746 37 Bålsta
Sweden

has been approved and awarded a labelling license

The labelling license is valid through:

30 April 2026

Danish Indoor Climate Labelling

*This certificate is subject to annual renewal according to the procedures of Danish Indoor Climate Labelling.
Danish Indoor Climate Labelling may withdraw the rights to use this certificate in case the manufacturer does not meet the requirements.*

Danish Indoor Climate Labelling

Certificate no. 013

Labelling license holder:

Gyproc

Saint-Gobain Denmark A/S
Hareskovvej 12
4400 Kalundborg
Denmark

Gyproc

Saint-Gobain Byggevarer AS
Habornveien 59
1630 Gamle Frederikstad
Norway

Gyproc

Saint-Gobain Sweden AB
Kalmarleden 50
746 37 Bålsta
Sweden

Product group

Gyptone Suspended Ceilings (prepainted and untreated surfaces) with or without Activ'Air properties

Testing and labelling criteria

General labelling criteria, 6th edition, 2018,
Ceiling and wall systems, 5th edition, 2018

Date of first issue of license

1 May 1995

Tested product(s)

Gyptone Quattro 50 Edge A

Evaluation of product group

EMISSION CLASS 1

PARTICLE CLASS LOW

The labelling license covers products considered to be identical with the tested product regarding emission and particle characteristics as specified by the labelling criteria. For a full list of products covered by the labelling license, see Appendix.

The emission class was determined based on the following measured values:

Measured values after 28 days	
TVOC ₂₈	0.16 mg/m ³
Formaldehyde ₂₈	< 0.005 mg/m ³
Sensory evaluation	
Time-value	30 days
Particle release	
	0.0 mg/m ²

Labelling license basis

The tested product(s) shows compliance with the DICL criteria for the present product group:

Emission measured after 3 days	
TVOC	≤ 10 mg/m ³
EU CARC 1A and 1B	≤ 0.01 mg/m ³
Emission measured after 28 days	
Sum of TVOC and SVOC with LCI	≤ 1.0 mg/m ³
EU CARC 1A and 1B	≤ 0.001 mg/m ³
R-value	≤ 1
Sensory evaluation	
Time-value	≤ 60 days

Particle class	
Low	≤ 0.75 mg/m ²
Medium	0.75 < x ≤ 2.00 mg/m ²
High	> 2.00 mg/m ²

Emission Class 1	TVOC ₂₈	≤ 0.5 mg/m ³
	Formaldehyde ₂₈	≤ 0.01 mg/m ³
Emission Class 2	TVOC ₂₈	≤ 1.0 mg/m ³
	Formaldehyde ₂₈	≤ 0.06 mg/m ³
Emission Class 3	TVOC ₂₈	≤ 1.0 mg/m ³
	Formaldehyde ₂₈	≤ 0.1 mg/m ³

Product information requirements

The holder of the labelling license is required to present the following product information on demand in order to avoid any adverse effects of the product on the indoor air quality in practice: product specifications, guidelines for transport, storage, assembly, cleaning and maintenance.

In the event of any discrepancies in the text arising from translation, the Danish text shall prevail.