

# Danish Indoor Climate Labelling

Certificate no. 013



Danish Indoor Climate Labelling hereby certifies that the product group:

## **Gyptone Suspended Ceilings (prepainted and untreated surfaces) with or without Activ'Air properties**

**Gyproc**  
Saint-Gobain Denmark A/S  
Hareskovvej 12  
4400 Kalundborg  
Denmark


**Gyproc AS**  
Habornveien 59  
1630 Gamle Frederikstad  
Norway

**Gyproc**  
Saint-Gobain Sweden AB  
Kalmarleden 50  
746 37 Bålsta  
Sweden

**has been approved and awarded a labelling license**

The labelling license is valid through:

**30<sup>th</sup> April 2023**

  
Danish Indoor Climate Labelling

This certificate is subject to annual renewal according to the procedures of Danish Indoor Climate Labelling. Danish Indoor Climate Labelling may withdraw the rights to use this certificate in case the manufacturer does not meet the requirements.

# Danish Indoor Climate Labelling

Certificate no. 013

Labelling license holder:

**Gyproc**

Saint-Gobain Denmark A/S  
Hareskovvej 12  
4400 Kalundborg  
Denmark

**Gyproc AS**

Habornveien 59  
1630 Gamle Frederikstad  
Norway

**Gyproc**

Saint-Gobain Sweden AB  
Kalmarleden 50  
746 37 Bålsta  
Sweden

Product group:

Gyptone Suspended Ceilings (prepainted and untreated surfaces) with or without Activ'Air properties

Testing and labelling criteria

General labelling criteria, 6th edition, 2018

Ceiling and wall systems, 5th ed. 2018

Date of first issue of license

1<sup>st</sup> May 1995

Tested product(s)

Gyptone Quattro 50 Edge A

Evaluation of product group

**EMISSION CLASS X**

**PARTICLE CLASS LOW**

The labelling license covers products considered to be identical with the tested product regarding emission and particle characteristics as specified by the labelling criteria. For a full list of products covered by the labelling license, see Appendix.

The emission and particle classes were determined based on the following measured values:

Measured values after 28 days	
TVOC <sub>28</sub>	0,16 mg/m <sup>3</sup>
Formaldehyde <sub>28</sub>	< 0,005 mg/m <sup>3</sup>

Sensory evaluation	
Time-value	30 days

Particle release	0,0 mg/m <sup>2</sup>
------------------	-----------------------

## Labelling license basis

The tested product(s) shows compliance with the DICL criteria for the present product group:

Emission measured after 3 days		
TVOC	≤	10 mg/m <sup>3</sup>
Carcinogens of EU cat. 1A and 1B	≤	0,01 mg/m <sup>3</sup>

Emission measured after 28 days		
Sum of TVOC and SVOC with LCI	≤	1,0 mg/m <sup>3</sup>
Carcinogens of EU cat. 1A and 1B	≤	0,001 mg/m <sup>3</sup>
R-value	≤	1

Sensory evaluation		
Time-value	≤	60 days

Particle class		
Low	≤ 0,75	mg/m <sup>2</sup>
Medium	0,75 < x ≤ 2,00	mg/m <sup>2</sup>
High	> 2,00	mg/m <sup>2</sup>

<b>Emission Class 1</b>	TVOC <sub>28</sub>	≤	0,5 mg/m <sup>3</sup>
	Formaldehyde <sub>28</sub>	≤	0,01 mg/m <sup>3</sup>
<b>Emission Class 2</b>	TVOC <sub>28</sub>	≤	1,0 mg/m <sup>3</sup>
	Formaldehyde <sub>28</sub>	≤	0,06 mg/m <sup>3</sup>
<b>Emission Class 3</b>	TVOC <sub>28</sub>	≤	1,0 mg/m <sup>3</sup>
	Formaldehyde <sub>28</sub>	≤	0,01 mg/m <sup>3</sup>

## Product information requirements

The holder of the labelling license is required to present the following product information on demand to avoid any adverse effects of the product on the indoor air quality in practice: product specifications, guidelines for transport, storage, assembly, cleaning and maintenance.

In the event of any discrepancies in the text arising from translation, the Danish text shall prevail.